



ROCK SHALL BE REMOVED WITHIN 6" OF ANY PART OF THE PIPE

PIPE SIZE	E
6" TO 24"	9"
27" TO 36"	12"

TOWN OF MIDDLETOWN

APPROVED: _____
DATE

03/13/15

STANDARD DETAIL

TRENCH DETAIL FOR
 DIP WATER LINE

REVISIONS:

W-2A