



NEW DROP MH

**NOTES**

1. PROVIDE RELINER INSIDE DROP SYSTEM MANUFACTURED BY DURAN INC. LYME, CT 860-434-0277 OR EQUAL
2. ALL HARDWARE SHALL BE 304 STAINLESS WITH 18-8 NUTS AND BOLTS.
3. BOWL SHALL "B" SIZE WITH SPIGOT END OF 8", 10" OR 12". LARGER DROP PIPES SHALL REQUIRE A 24" BOWL. ATTACH BOWL TO WALL WITH 3/8" SS BOLTS AND WASHERS IN EXPANSION ANCHORS.
4. THE SANITARY INLET PIPE SHALL PROTRUDE 2" FROM THE INSIDE OF WALL. CUT A "V" IN THE INLET PIPE.
5. FLEXIBLE EXTERNAL PIPE COUPLER SHALL BE FERNCO OR EQUAL WITH STAINLESS STEEL BANDS.
6. FOLLOW MANUFACTURER'S RECOMMENDED INSTALLATION INSTRUCTIONS.
7. FOR PRECAST MANHOLE REQUIREMENTS SEE APPROPRIATE DETAIL.

<p>TOWN OF MIDDLETOWN</p> <p>APPROVED: _____</p> <p style="text-align: center;">10-29-03 DATE</p>	<p>STANDARD DETAIL</p>	<p>REVISIONS:</p>	<p>S-9</p>
	<p>INSIDE DROP</p>		
	<p>DETAIL</p>		