



NOTES

1. PIPE TO BE HDPE MEETING AASHTO M252 OR M294
2. FILTER FABRIC SHALL BE MSHA SD TYPE I (LINQ150EX OR EQUAL).
3. GROUT DRAIN TO INLET BASE. PIPE PENETRATION TO BE FORMED OR CORE DRILLED.

<p>TOWN OF MIDDLETOWN</p>	<p>STANDARD DETAIL</p>	<p>REVISIONS:</p>	<p>SW-3</p>				
<p>APPROVED: _____</p> <p style="text-align: center;">DATE</p>	<p>UNDER DRAIN</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="height: 20px;"> </td></tr> <tr><td style="height: 20px;"> </td></tr> <tr><td style="height: 20px;"> </td></tr> <tr><td style="height: 20px;"> </td></tr> </table>					