



NOTES:

1. IRON CASTINGS SHALL BE DOMESTICALLY MANUFACTURED.
2. BRASS SHALL BE MANUFACTURED BY FORD METER BOX OR MUELLER CO
3. COPPER TUBING SHALL HAVE NO JOINTS FROM CORP STOP TO METER VAULT.
4. IF THIS IS A NEW SERVICE WITHOUT CONNECTION TO AN EXISTING PIPE PROVIDE THE DAPTOR AND PLASTIC PLUG.
IF THIS IS A CONNECTION TO AN EXISTING SERVICE PROVIDE THE PROPER ADAPTOR FOR THE TYPE OF TUBING OR PIPE REQUIRED.
5. CONTRACTOR TO PROVIDE PVC JUMPER IN COPPER SETTING UNTIL METER IS INSTALLED.
6. AN ALTERNATIVE FRAME AND COVER, A. Y. MCDONALD MODEL 74R3AC WITH OPTIONS ON THE TYPE "R" COVR OF TC AND RTC CAN BE USED. THIS COVER SHALL BE USED WHEN THE ELEVATION OF THE LID NEEDS TO BE ADJUSTED IN A RETROFIT SITUATION.

- A FORD WASBASH W3-D-C-T ID DOUBLE LID COVER WITH SINGLE TOUCHREAD HOLE
 C 24" DIAMETER X 36" DEPTH METER PIT POLYETHYLENE VAULT 20" BULLET BODY STYLE
 D FORD VBHC74-24444QNL SETTER (1", BALL VALVE, DUAL CHECK, QUICK CONNECTIONS)
 E 1" QUICK X FIP ADAPTOR WITH PLASTIC THREADED PLUG
 F 1" METER AND MXU PROVIDED BY TOWN
 G NATURAL SAND BEDDING (3" MIN W/ 8" BACKFILL)
 H 1" PVC JUMPER

<p>TOWN OF MIDDLETOWN</p>	<p>STANDARD DETAIL</p>	<p>REVISIONS:</p>	<p>W-7</p>												
<p>APPROVED: _____</p> <p style="font-size: small;">05/13/20 DATE</p>	<p>1" OUTSIDE METER SETTING</p>	<table border="1" style="width: 100%; height: 40px; border-collapse: collapse;"> <tr><td style="width: 50%; height: 15px;"> </td><td style="width: 50%; height: 15px;"> </td></tr> <tr><td style="width: 50%; height: 15px;"> </td><td style="width: 50%; height: 15px;"> </td></tr> <tr><td style="width: 50%; height: 15px;"> </td><td style="width: 50%; height: 15px;"> </td></tr> </table>							<table border="1" style="width: 100%; height: 40px; border-collapse: collapse;"> <tr><td style="width: 50%; height: 15px;"> </td><td style="width: 50%; height: 15px;"> </td></tr> <tr><td style="width: 50%; height: 15px;"> </td><td style="width: 50%; height: 15px;"> </td></tr> <tr><td style="width: 50%; height: 15px;"> </td><td style="width: 50%; height: 15px;"> </td></tr> </table>						